



JA Structural Consulting
1124 Central Ave, Needham, MA, 02492
PHONE 1.617.416.2023
JAstructural@gmail.com

September 11, 2025

ATTN: ReVision Energy
1980 Turnpike St building 2
North Andover, MA 01845

RE: Structural Affidavit for
Santo Residence Solar Panel Installation
212 Lions Mouth Rd
Amesbury, MA 01913

To Whom It May Concern,

I am writing in regards to the solar panel installation project at Santo Residence on 212 Lions Mouth Rd, Amesbury, MA 01913. A field inspection was conducted upon the completion of installation and data were gathered by ReVision Energy staffs. The following is a summary of my findings.

The products that were used in this project, such as the PV panels, racking systems, and accessories are consistent with these on the permit plan sheets.

Roof 1 structure as existing **is** adequate to withstand all loading from the panels, snow and wind.


All applicable loads required by **IRC 2015** and with **Massachusetts amendments** were applied to the **Ironridge rail system** and roof connections and analyzed. Finally, I accept the certifications indicated by the solar panel manufacturer for the ability of the panels to withstand high wind and snow loads

Do not hesitate to contact my office at 617-416-2023 should you have any questions or if you require any additional information.

Respectfully,
JA Structural Consulting

A handwritten signature in blue ink, appearing to read "Pola Arsanious".

Pola Arsanious, P.E.



Santo Residence