



August 31, 2023

Amesbury Conservation Commission
62 Friend Street
Amesbury, MA 01913

RE: 20 Pond Street, Amesbury, MA – DEP File #002-1209
Request for Certificate of Compliance

Dear Commissioners,

Pursuant to the Order of Conditions, the letter certifies the work was completed in substantial compliance with the approved plans of record. The provided as-built indicated the completed work on the property. The site is stable with no indication of erosion even with the extreme rain events recently experienced. The minor changes versus the plan of record include the following items.


1. The parking spaces are partially finished with a pea gravel surface with permeable paver apron at the entry doors. This change still provides a permeable surface maintaining the intent of the original design with the substituted surface providing an enhanced rate of permeability versus the approved plans.
2. The wall was constructed as a cast in place concrete wall versus a large block gravity system. This has no environmental impact other than reducing the wall cross section and any impermeable surface created by the wall system.

The above referenced changes have no impact and could be considered an improved condition versus the design intent of original design plans. It should be noted that there is no evidence of any concentrated runoff or erosion from the property into the Powow river confirmed by the loose straw covering the new landscape planting situated fully in place and not washed up against the erosion control line. Please see the attached site photographs of the property and contact me with any questions pertaining to the completed work.


Sincerely,
GM2 Associates, Inc.

Stephen Sawyer

Stephen Sawyer P.E.
Senior Project Manager



Pea Gravel Drive



Permeable Paver landing



Rear Planting and Stone Infiltration Edge



Rear Planting and Stone Infiltration Edge